



CONCRETE SWALE

NOTES

1. CONCRETE COMPRESSIVE STRENGTH = 32 MPa
2. MAXIMUM AGGREGATE SIZE = 20mm
3. MAXIMUM SLUMP = 75mm
4. CONTRACTION JOINTS SHALL BE CONSTRUCTED @ INTERVALS OF 1.5m WITH GROOVES APPROX. 3mm IN WIDTH AND SHALL EXTEND 1/4 THE DEPTH OF THE STRUCTURE
5. CONTRACTION JOINTS SHALL BE CONSTRUCTED IN ALL CROSSINGS AT INTERVALS OF 4m OR AT THE CENTRE OF CROSSINGS 6m OR LESS IN WIDTH

	CITY OF PRINCE ALBERT PUBLIC WORKS	APPROVED <i>Wes Hicks</i>
	CONCRETE SWALE DETAIL	SCALE N.T.S.
No.	DATE	REVISION
	DRAWN S. NUMEHAHL	DESIGNED N. MILLER
	DATE OCT. 2014	
	DWG. No. 00-03-08	